



Paul R. LePage
GOVERNOR

STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

David Bernhardt
COMMISSIONER

March 20, 2015
Subject: **steel fabrication**
NO WIN: PH020504.00
Location: **Passadumkeag**
Amendment No. 1

Dear Sir/Ms:

The following questions have been received:

Question: Can we substitute 4" x 3-1/2" x 1/2" thick angles for the 4" x 3-1/2" x 7/16" thick angles

Response: No, these materials are replacing existing members in a truss and we need to match the existing members to ensure a good fit.

Question: Will we need to submit shop drawings for approval or can we fabricate from the contract drawings?

Response: Shop drawings will not be required, fabrication based on the contract drawings will work.

Question: Will you need bolt samples to be tested by MDOT?

Response: Yes.

Consider this information prior to submitting your bid on **April 1, 2015**.

Sincerely,

George M. A. Macdougall P.E.
Contracts & Specifications Engineer



PRINTED ON RECYCLED PAPER